



## EU Declaration of Conformity

### CFP Conventional Fire Panels

#### Product Model Designation(s) & Description(s)

- CFP702E-4 CFP Economy 2 Zone Panel \*
- CFP704E-4 CFP Economy 4 Zone Panel \*
- CFP708E-4 CFP Economy 8 Zone Panel \*
- CFP702-4 CFP Standard 2 Zone Panel \*
- CFP704-4 CFP Standard 4 Zone Panel \*
- CFP708-4 CFP Standard 8 Zone Panel \*
- CFP702-4/R CFP Standard 2 Zone Panel, Red Housing \*
- CFP704-4/R CFP Standard 4 Zone Panel, Red Housing \*
- CFP708-4/R CFP Standard 8 Zone Panel, Red Housing \*
- CFP702-2 CFP Alarmsense Two Wire 2 Zone Panel \*
- CFP704-2 CFP Alarmsense Two Wire 4 Zone Panel \*
- CFP704-2 CFP Alarmsense Two Wire 8 Zone Panel \*
- CFP760 CFP 8 Zone Repeater Panel

#### Manufactured by C-TEC at:

Computationics Ltd (Trading as C-TEC) Challenge Way, Martland Park, Wigan, WN5 0LD, United Kingdom

#### are in conformity with the provisions of the following EU Directive(s):

- 2014/30/EU: Electromagnetic Compatibility Directive (EMC)
- 2014/35/EU: Low Voltage Directive (LVD)
- 2011/65/EU: Restriction of Use of certain Hazardous Substances Directive (RoHS)

Note: the products marked with an asterisk (\*) are also in conformity with the Construction Products Regulation (CPR) for which a separate Declaration of Performance (DoP) is provided and may be obtained by emailing [marketing@c-tec.co.uk](mailto:marketing@c-tec.co.uk)

#### The products to which this declaration relates have been tested to and are in conformity with the following standards:

- EN 50130-4: 2011+A1:2014  
Alarm Systems – Part 4: Electromagnetic Compatibility - Product family standard: Immunity requirements for components of fire, intruder and social alarm systems.
- EN 61000-6-3: 2007+A1:2011  
Electromagnetic compatibility (EMC) – Part 6-3: Generic Standards - Emission standard for residential, commercial and light-industrial environments.
- EN 62368-1:2014  
Audio/Video, Information & Communication Technology Equipment — Safety — Part 1: Safety Requirements
- BS EN IEC 63000:2018 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

#### In addition, the products satisfy the essential requirements of the following standards:

- EN54-2: 1997 + A1:2006  
Fire detection and fire alarm systems – Control and indicating equipment
- EN54-4: 1997 + A1:2002 + A2:2006  
Fire detection and fire alarm systems – Power supply equipment

#### Empowered Signatory of Company

I, the undersigned, hereby declare on behalf of Computationics Limited that the products listed above comply with the requirements of the standards listed above which gives presumption of conformity with the essential requirements of the directives listed above.

Name: Daniel Foster

Place: Wigan, UK

Position: Head of Science

Signature:

Date: 08/07/2022