

Type A Outdoor Manual Call Point with Isolator **EV-MCP2-SCI-IP67**

Part no. FI6-82205

General Description

EV-MCP2-SCI-IP67 is a Type A Outdoor Manual Call Point, with integral –ve line Short circuit isolator compatible with Evolution analogue addressable system devices.

The Manual Call Point comprises a Non Frangible, Resettable, operating face with an LED provided to Indicate Alarm active condition.

The device is provided with a waterproof Backbox with knock-outs and M20 threads for easy fitment of Cable glands.

The address may be set using DIL switch on the Device.

The Short Circuit Isolator will protect the system, whilst allowing the device to continue communication from the opposite side. The isolator will self-reset when the fault clears.

Approvals

Test Standards	EN54-11:2001 + A1:2005
	EN54-17: 2005 / AC: 2007
CPR Certificate	0905-CPR-00440
UKCA Certificate	0359-UKCA-CPR-00003
DoP Number	00440

Notes

Not compatible with Advanced MxPro4 (Mx4000) Panel. Please use Non-SCI model.

It is not possible to mix +ve and -ve isolator styles on a system.

Data

Data			
Manual Call Point Type T		Гуре A Outdoor	
Operating Method		Non Frangible, Resettable	
Operating Element		Microswitch	
Operating loop voltage		20 to 38 Vdc	
Quiescent current		200 µA	
Alarm current 2		2 mA (LED On)	
Current in short circuit		I3 mA	
Operating temperature -2		25°C to +70°C	
Storage temperature		-25°C to +70°C	
Relative humidity <		RH 95% (Non-condensing)	
Cable terminals	0.75	0.75 to 2.5 mm ²	
Material F		°C	
Weight	280	g	
Dimensions	88mm x 90mm x 72mm		
I.P. Protection Rating IP		267	
Short Circuit Isolator			
Minimum sw open voltage (Vso min)		Vdc	
Maximum sw open voltage (Vso max)		I Vdc	
Minimum sw close voltage (Vsc min)		0 Vdc	
Maximum sw close voltage (Vsc max)		3 Vdc	
Maximum line current (lc max)		800 mA	
Maximum switching current (Is max)		500 mA	
Maximum leakage current (II max)		3 mA	
Maximum switch resistance (Zc max)		50 mΩ	

All wiring must conform to the current edition of IEE Wiring regulations and BS5839 Part I

All loop Cable Screens shall be connected together, but must be Isolated from Ground. Cable Screens shall be connected to Earth Ground within the Control Panel ONLY.



Dimensions mm



Connections



